If you are using a printed copy of this procedure, and not the on-screen version, then you MUST make sure the dates at the bottom of the printed copy and the on-screen version match.
The on-screen version of the Collider-Accelerator Department Procedure is the Official Version.
Hard copies of all signed, official, C-A Operating Procedures are kept on file in the C-A ESHQ Training Office, Bldg. 911A.

C-A OPERATIONS PROCEDURES MANUAL

7.1.15 Heat Exchanger 1A/2A Online and Heat Exchanger 1B/2B Offline

Text Pages 2 through 4

Hand Processed Changes

HPC No.	Date	Page Nos.	Initials

Approved: _____***Signature on File***_____ _____
Collider-Accelerator Department Chairman Date

D. Lederle

7.1.15 Heat Exchanger 1A/2A Online and Heat Exchanger 1B/2B Offline

1. Purpose

This procedure provides instructions for placing heat exchanger 1A/2A online and taking heat exchanger 1B/2B offline. This procedure will be performed when heat exchanger 1B/2B is contaminated and being taken offline for regeneration. The steps necessary to regenerate heat exchanger 1B/2B are not covered under this procedure, please reference C-A OPM 7.1.18.

2. Responsibilities

2.1 The Shift Supervisor, or an Operator designated by the Shift Supervisor, is responsible for conducting the procedure and providing documentation in the Cryogenic Control Room Log.

2.2 Should a problem arise in the process of switching heat exchangers, the Shift Supervisor shall report to the Technical Supervisor for instructions before continuing.

3. Prerequisites

3.1 Operator shall be familiar with the refrigerator P&ID drawing 3A995009, the physical location of components on the refrigerator, and the refrigerator control pages found on the CRISP control system.

3.2 Heat exchanger 1A/2A regenerated, per C-A-OPM 7.1.17, "Regeneration of Heat Exchanger 1A/2A". Heat exchanger 1A/2A is clean and ready for service if the low pressure outlet valve and high pressure inlet valves are open.

3.3 Oxygen monitor and hygrometer in compressor room are set to read compressor discharge.

4. Precautions

4.1 If there is liquid helium in the refrigerator pots, all personnel entering the refrigeration wing of 1005R must be ODH Class 1 qualified, have a Personal Oxygen Monitor (POM), and carry an emergency escape pack.

5. Procedure

_____ 5.1 Date _____

_____ 5.2 Ensure DP instrument valve H312M is closed.

_____ 5.3 Ensure DP instrument valves H442M_____ and H421M_____ are open.

_____ 5.4 If during this procedure, any sustained increase in dew point at compressor discharge appears, stop this procedure and regenerate heat exchanger as per C-A-OPM 7.1.18.

_____ 5.5 Crack open valve H313M to begin the cool down of heat exchanger 1A/2A

_____ 5.6 Monitor the temperature of running warm turbine train. If in auto, turbines should compensate as necessary.

_____ 5.7 Monitor heat exchanger low pressure inlet temperature sensor TI304. Also monitor TI965, TI966, and TI967 on low pressure side of heat exchanger 1A/2A. The desired temperature drop is 5°K/15 minutes on the heat exchanger sensors, while the inlet temperature to the running turbine train is maintained.

_____ 5.8 When sensors TI308, TI309, and TI310 on high pressure side of heat exchanger 1A/2A come within 10°K of sensors TI708, TI709, and TI710 located on high pressure side of heat exchanger 1B/2B, crack open valve H314A.

_____ 5.9 Monitor TI210 and if it increases by more than 10°K in 15 minutes, throttle back valve H314A.

_____ 5.10 When TI210 returns to its initial temperature, slowly open valve H313M _____ and H314A _____at the same rate. Adsorber temperature (should stay below 90°K) and compressor suction temperature (should stay above 260°K).

_____ 5.11 Crack open valve H324M.

_____ 5.12 Monitor the inlet temperature of running turbine train (TI334 on turbine train A, TI734 on turbine train B). If the inlet temperature increases by more than 5°K, adjust valve H324M until the inlet turbine temperature becomes stable.

_____ 5.13 Open valve H324M fully when the inlet turbine temperature becomes stable.

_____ 5.14 Close valve H724M.

_____ 5.15 Monitor the inlet temperature of running turbine train (TI334 on turbine train A, TI734 on turbine train B). If the inlet temperature increases by more than 5°K, reopen valve H724M.

_____ 5.16 If valve H724M has to be reopened, repeat above steps as necessary until the inlet temperature of the running turbine train is stable with valve H724M fully closed.

_____ 5.17 When valve H724M remains fully closed, close the following valves on heat exchanger 1B/2B:

H714A_____ H715M_____ H716M_____ H717M_____ H713M_____

_____ 5.18 Vent the high pressure side of heat exchanger 1B/2B down to 10 atmospheres, as read on PI844H thru valves H719M, H721M and H723M.

_____ 5.19 If heat exchanger 1B/2B was taken offline due to contamination, start regeneration process as specified in C-A OPM 7.1.18.

6. Documentation

6.1 The check-off lines on the procedure are for place-keeping only. The procedure is not to be initialed or signed, it is not a record.

6.2 The Shift Supervisor, or designee, shall document the completion of the procedure in the Cryogenics Control Room Log

7. References

7.1 Drawing 3A995009, 25kw Helium Refrigerator P & ID.

7.2 C-A-OPM 7.1.18, "Regeneration of Heat Exchanger 1B/2B".

7.3 C-A-OPM 7.1.17, "Regeneration of Heat Exchanger 1A/2A".

8. Attachments

None