



# Memo

*date: January 20, 2004*

*to: Distribution*

*from: A. Piper*

*subject: "Safety-Walk"*

*On Friday, January 16, 2004 at 13:30 hours, A "Safety-Walk" was performed focusing on ongoing work on the Jet Target in building 930.*

*Safety-Walk Attendees:*

*Arthur Piper (C-A ESHQ)*  
*Peter Cirnigliaro (C-A ESHQ)*  
*G. Mahler (Engineering)*  
*W. Shaffer (Linac Technical staff)*  
*T. Curcio (Instrumentation Technical Staff)*

*Task: Ongoing assembly/modification/testing of Jet Target*

*Positive Observations:*

- Entry doors were posted as magnetic field areas*
- Enhanced Work Permit was posted at the job site*
- Test area was kept free of debris and aisles were maintained*
- Scaffold is erected correctly*

*Negative Observations:*

- Portable chiller was positioned in front of electrical disconnects*
- Scaffold access is improper*
- Heavy items are stored on top of shelves/cabinets*
- Portable chiller supply lines should be plumbed in to eliminate trip hazards in hallway*
- Equipment/packaging materials are stored in hallway*
- There is no fire extinguisher located in the test area*

*Recommended corrective actions for negative observations will be assigned and tracked to completion in the ATS family tracking system.*

*Distribution: Safety-Walk attendees*

*R. Karol*

*E. Lessard*

*D. Lowenstein*