REV.	ZONE	ECN NO.	DATE	BY	CKR	APP.

Controls, C-AD 10/6/2003 3:44 PM d36-e1126_3.dwg



F/O TX
F/O RX
F/O TX OR RX CARD
94028164 (TX)
94028097 (RX)

CONNECTOR

F/O TX/RX — ETHERNET TRANSCEIVER

SPLICE — FUSION SPLICE

F/O TX / F/O RX — MATH ASSOC. TX OR RX

INTERBUILDING CABLE IS A 24 FIBER LOOSE TUBE ARMORED CABLE, EXCEPT 921-919 WHICH IS A 18 FIBER CABLE.

ALL CABLES ARE 62.5/125 FIBER.

-3	-2	-1	REF DESIGNATOR	ITEM NO.	DESCRIPTION	MAT'L. DWG NO.,SPL NO.
QTY REQD						

INTERPRET IN GENERAL ACCORDANCE WITH ASME Y14.24M-1989

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES

DECIMAL TOLERANCES
.X ±.030
.XX ±.015
.XXX ±.005
ANGULAR TOLERANCE ± .5°

OUTSTANDING ECN

NA FINISH

BREAK SHARP EDGES
MAX. XX MIN. XX

Q.A. CATEGORY A-3		DATE	BROOKHAVEN NATIONAL LABORATORY
DRAWN BY	Ed Koropsak	9/4/03	UPTON, N.Y. 11973
CHECKED BY	NOBODY		AGS CONTROLS
DESIGN APPROVAL			FIBER OPTIC PATHS
ENGINEER APPROVAL	NONE		929 LINE
SUPVR. APPROVAL			
NEXT ASSEMBLY			SIZE D — D36-E1126 — REV. A (DRAWING NUMBER)
			MATERIAL: — SCALE: FULL WEIGHT: – SHEET 3 OF 8

*AUTOCAD